



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2020714
Permit #: 00846-2024CAT
Request Rec'd: 07/17/2024
Approval Date: 07/17/2024
Permit Expires: 01/17/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Chicago Transit Authority 567 W. Lake St Chicago, IL 60661 Cook County Contact: Shile Liang 312/681-2747	FACILITY - name and address where tanks are located: 77th Street Bus Garage 7801 S. Vincennes Ave. Chicago, IL 60620 Cook County Contact: Symone Amos 312/681-2782
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
34	Diesel Fuel	6,000	Out of service	Federal
35	Motor Oil	6,000	Currently in use	Federal

Tank 34 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

Tank 35 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks


Special Contingencies

Summary of Work

Adding Sac Anodes 9# on Tank #34 & Tank #35 on piping in containment.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: 262/268-1150 Email: frankg@protanicinc.com Contractor License # IL1413 Exp. 3/15/2026

Sincerely,

A handwritten signature in black ink that reads "Seán Keane". The signature is written in a cursive style with a horizontal line underneath the text.

Sean Keane