



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2039903
Permit #: 00845-2024UPG
Request Rec'd: 07/17/2024
Approval Date: 07/17/2024
Permit Expires: 01/17/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Ibrahim Mubarak 9124 South Thomas Avenue Bridgeview, IL 60455 Cook County Contact: Ibrahim Mubarak 312/774-2400	FACILITY - name and address where tanks are located: Garfield Gas 2006 W Garfield Chicago, IL 60609 Cook County Contact: Khalid Siddiqui 773/406-7777
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	6,000	Currently in use	Federal
3	Diesel Fuel	5,000	Currently in use	State

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

Existing single wall spill buckets on tank 2 and 3 and failing test. we are replacing failed spill buckets with double wall spill buckets. Spill bucket testing will be provided right after the completion of job.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
American Petroleum Solutions LLC 2911 Lund avenue apt 8 Rockford, IL 61109	Contact Person: Haibat Khan Phone: 909/312-9449 Email: apetro.office@gmail.com Contractor License # IL002454 Exp. 5/21/2026

Sincerely,

Sean Keane