

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 6009205
Permit #: 00847-2024UPG
Request Rec'd: 07/17/2024
Approval Date: 07/17/2024 DS
Amended Date:07/22/2024 DS
Permit Expires: 07/30/2024

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Midwest Petroleum Company 220 Old Meramec Station Rd. Manchester, MO 63021

(None) County

Contact: Tony Koenig 636/220-3800

FACILITY

- name and address where tanks are located:

Midwest Petroleum #34 1200 Royal Heights Road Belleville, IL 62221 St. Clair County

Contact: Fred Vesper 618/223-4222

Tanks on the Permit

Tan	ık#	Product	Capacity	Tank Status	Regulated Status
3	3	Gasoline - Regular	10,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser	New

Summary of Work

Replace a bad tank probe riser due to water intrusion into tank 3,

Special Contingencies

Amendment Reason:

This permit should have been for tank 3 UL

PERSON, FIRM OR COMPANY PERFORMING WORK:

UPC Enterprises, LC d/b/a United Petroleum Service

128 Millwell Drive

Maryland Heights, MO 63043

Janiel J. Starke

Contact Person: Terry Smith Phone: 314/267-1231

Email: terrys@unitedpetro.com

Contractor License # IL002402 Exp. 2/10/2026

Sincerely,

Daniel Starks