



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4038972
Permit #: 00873-2024UPG
Request Rec'd: 07/23/2024
Approval Date: 07/23/2024 DS
Permit Expires: 01/23/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Guru Krupa Gas & Liquor 1601 Old State Road Mattoon, IL 61938 Coles County Contact: Himanshu (Harry Amin 217/690-7855	FACILITY - name and address where tanks are located: S & H Gas & Liquor 1601 Old State Road Mattoon, IL 61938 Coles County Contact: Himanshu (Harry) Amin 217/234-7625
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Premium	8,000	Currently in use	Federal
3	Diesel Fuel	4,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Corrosion Protection - Piping	Polyethylene Chase	New
Piping	Flexible Double Wall A.P.T. Poly Tech S175SC	Replacing - Piping - Flexible Double Wall
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - STP/Tanktop Sump containment FRP
Leak Detection - Piping	Sump Sensor	Reusing Existing

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - STP/Tanktop Sump containment FRP
Leak Detection - Piping	Sump Sensor	Reusing Existing
Corrosion Protection - Piping	Flexible Non-Corrosive	Replacing - Corrosion Prot - Piping - Flexible Non-Corrosive
Piping	Flexible Double Wall A.P.T. Poly Tech S175SC	Replacing - Piping - Flexible Double Wall
Corrosion Protection - Piping	Polyethylene Chase	New
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - STP/Tanktop Sump containment FRP
Leak Detection - Piping	Sump Sensor with positive shutdown	Reusing Existing

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

After removal, we will be installing new FRP STP sumps on all 3 tanks. Installing new APT 175 piping in a chase from tanks 1 and 2 to the 3 dispensers out front. Reconnecting existing piping to tank 3. Reusing the sensors in the STP sumps along with the existing overfill alarm. Installing new Franklin Fueling poly UDC sumps and sump sensors for dispensers 1-6. Reusing existing dispensers. Installing new tank risers and double wall spill buckets. Reusing existing tank probes and TLS system. Tank 3 STP motor will be reused and will install new FE Petro STP's on tanks 1 and 2. Replacing with new mechanical red jacket leak detectors.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Glen Davis
Phone: 515/601-6635
Email: jfranklin@senecaco.com
Contractor License # IL598 Exp. 2/23/2026

Sincerely,



Daniel Starks

For Office Use Only**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing