

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov Amended FOR OFFICE USE ONLY

Facility #: 2024542
Permit #: 00841-2024CAT
Request Rec'd: 07/16/2024
Approval Date: 07/16/2024 DS
Amended Date:07/23/2024 SB
Permit Expires: 01/16/2025

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Habes Abdallah 4000 Southwest Hwy. Hometown, IL 60453 Cook County

Contact: Habes Abdallah 708/351-5233

FACILITY

- name and address where tanks are located:

Hometown Mobil 4000 Southwest Hwy. Hometown, IL 60456 Cook County

Contact: Ahamad Zahdan 312/375-9105

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Regular	12,000	Currently in use	Federal
3	Gasoline - Premium	12,000	Currently in use	Federal
4	Diesel Fuel	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

Special Contingencies

Amendment Reason:

Removing Tank 9 as this tank was not to be upgraded to CP

Summary of Work

Install 1 9lb anode in each dispenser 1/2 and 7/8 per NOV

PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC

658 North Progress Drive PO Box 80265

Saukville, WI 53080

Daniel J. Starks

Contact Person: Kylie Krombach

Phone: 262/268-1150

Email: emilya@protanicinc.com

Contractor License # IL1413 Exp. 3/15/2026

Sincerely,

Daniel Starks