



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 4011115  
Permit #: 00887-2024UPG  
Request Rec'd: 07/25/2024  
Approval Date: 07/25/2024 DS  
Permit Expires: 01/27/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Moto, Inc. 721 W. Main Street Belleville, IL 62222 St. Clair County Contact: Shane Maxey 618/233-6754	<b>FACILITY</b> - name and address where tanks are located: Shelbyville Motomart 1003 Main Street Shelbyville, IL 62565 Shelby County Contact: Rose Coleman 217/774-5710
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Mid-grade	10,000	Currently in use	Federal
6	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket - Northwest	Replacing - Spill Contain Device - Single Wall Spill Bucket

**Summary of Work**

repalce SW Spill buckets with new DW spill buckets

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720	Contact Person: Mark Hinderliter Phone: 812/425-4137 Email: permits@hci4.com Contractor License # IL646 Exp. 7/3/2026

Sincerely,

Daniel Starks