



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 2010018  
Permit #: 00878-2024UPG  
Request Rec'd: 07/24/2024  
Approval Date: 07/24/2024 DS  
Amended Date: 07/29/2024 DS  
Permit Expires: 01/24/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Land Mart, Inc. 15 E. Sibley Blvd South Holland, IL 60673 Cook County Contact: Saju Kannampallil 708/253-9293	<b>FACILITY</b> - name and address where tanks are located: Arco 15 E. Sibley Blvd. South Holland, IL 60473 Cook County Contact: Saju Kannampallil 847/791-1824
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	12,000	Currently in use	Federal
6	Gasoline - Premium	6,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New

**Summary of Work**

UPDATED ON 07/29/2024 FOR AMENDMENT: Owner decided not to put Tank 4 back in service.

Per the existing NOV, we will be disconnecting the line below the shear valves and above the flex connectors to add fittings to raise the shear valves to correct height.

**Special Contingencies**

**Amendment Reason:**

Owner is not putting Tank 4 back into service

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks