



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2011002
Permit #: 00907-2024UPG
Request Rec'd: 07/29/2024
Approval Date: 07/30/2024 DS
Permit Expires: 01/30/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Illinois State Toll Highway Authority 2700 Ogden Avenue Downers Grove, IL 60515 Du Page County Contact: Gerald Dillon 847/212-4024	FACILITY - name and address where tanks are located: ISTHA M06 Maintenance Garage Route 20 & I-90 Northwest Tollway, Mile Post 36.5 Hampshire, IL 60140 Kane County Contact: Eric Johnson 847/683-2179
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
11	E85	10,000	Currently in use	Federal

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser	New

Summary of Work

Install new double walled spill bucket, overfill drop tube and new riser for E-85 tank

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks