

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2018734
Permit #: 00912-2024UPG
Request Rec'd: 07/29/2024
Approval Date:07/31/2024 DS
Permit Expires: 01/31/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Northern Illinois Medical Center

10400 Haligus Rd. Huntley, IL 60142 McHenry County

Contact: Mike Bentley 224/654-0462

FACILITY

- name and address where tanks are located:

Northern Illinois Medical Center 4201 Medical Center Drive

McHenry, IL 60050 McHenry County

Contact: Mike Ambroz 815/344-5000

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action	
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket	
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve	
Piping	Other Steel Riser	New	

Summary of Work

Installing new fill riser, probe riser, double wall spill bucket and overfill drop tube

Special Contingencies

Janiel y. Starke

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 630/878-6354
Email: jasonre@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks