



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 6009205
Permit #: 00921-2024UPG
Request Rec'd: 08/02/2024
Approval Date: 08/02/2024 SB
Permit Expires: 02/04/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Midwest Petroleum Company 220 Old Meramec Station Rd. Manchester, MO 63021 (None) County Contact: Tony Koenig 636/220-3800	FACILITY - name and address where tanks are located: Midwest Petroleum #34 1200 Royal Heights Road Belleville, IL 62221 St. Clair County Contact: Fred Vesper 618/223-4222
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Ball Float Vent Valve

Summary of Work

Driver overfilled the tank which caused the ball to come out of its cage. Therefore, we will be replacing the overfill device with a new drop tube.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
JDM Petroleum Service 220 Meramec Station Rd Manchester, MO 63021	Contact Person: Kline Jeff Phone: 573/450-9775 Email: dustin.woeltje@jdmpetro.com Contractor License # IL002451 Exp. 7/15/2025

Sincerely,

Shelly Bradley