



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 312/745-3162
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2022995
Permit #:	00940-2024CAT
Request Rec'd:	08/06/2024
Approval Date:	08/06/2024
Permit Expires:	02/06/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: CVS Gas & Food, Inc. 1852 Morgan Circle Naperville, IL 60565 Du Page County Contact: Mohammad Zahir 630/235-1947	FACILITY - name and address where tanks are located: BP - 8648 Jeffery 8648 S. Jeffery Chicago, IL 60617 Cook County Contact: Mohammad Zahir 630/235-1947
--	--

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Gasoline - Regular	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - East	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - North	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - East	New

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work


Install 1 (one) 9 lb anode in each of the 3 STP sumps.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC
658 North Progress Drive PO Box 80265
Saukville, WI 53080

Contact Person: Kylie Krombach
Phone: 262/268-1150
Email: jackiee@protanicinc.com
Contractor License # IL1413 Exp. 3/15/2026

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive style and is positioned above a solid horizontal line.

Sean Keane