



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 1022842
Permit #: 00944-2024UPG
Request Rec'd: 08/06/2024
Approval Date: 08/06/2024 DS
Permit Expires: 02/06/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Elizabeth Sauser 210/692-2224	FACILITY - name and address where tanks are located: Circle K #41 1030 East State Street Rockford, IL 61104 Winnebago County Contact: Amanda DeLong 815/967-8875
--	---

Dispensers on the Permit

Dispenser	Action
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
9/10	Sump / Sensors Changing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown	Replacing - Leak Detect - Piping - Sump Sensor

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor

Summary of Work

replacing UDC sump sensors at dispensers 3/4, 5/6, and 9/10 with positive shut down

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026

Sincerely,

Daniel J. Starks

Daniel Starks