



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 1011629
Permit #: 00904-2024CAT
Request Rec'd: 07/29/2024
Approval Date: 07/29/2024 DS
Amended Date: 08/08/2024 DS
Permit Expires: 01/29/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Bud's Citgo Service, Inc. 150 East Market Street Somonauk, IL 60552 De Kalb County Contact: Robert Grandgeorge 815/498-2217	FACILITY - name and address where tanks are located: Bud's Citgo Service, Inc. 150 East Market Street Somonauk, IL 60552 De Kalb County Contact: Bob Honkala 815/498-2217
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Gasoline - Regular	15,000	Currently in use	Federal
10	Gasoline - Premium	6,000	Currently in use	Federal

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Cathodic Protection	New

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Amendment Reason:

There was a misunderstanding on what needed to have cp installed on. we thought it was the STP. Fter talking to Charlene with the Fire Marshals office it neede to be installed on the #5/6 Dispenser UDC.

Summary of Work

We are adding 10LBS Anode tubes to the metal fittings in the 5/6 dispenser UDC becouse sumps contain water. .

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Pipeco, Inc. 610 29th Street Bettendorf, IA 52722	Contact Person: Robert Schafer Phone: 563/529-8502 Email: rob@pipecoinc.com Contractor License # IL2034 Exp. 9/28/2024

Sincerely,

Daniel J. Starks

Daniel Starks