



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047779
Permit #: 00959-2024ABN
Request Rec'd: 08/07/2024
Approval Date: 08/09/2024 DS
Permit Expires: 02/11/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Bruce Horek 109 Pine ST Elmhurst, IL 60126 Contact: Bruce Horek 708/567-2424	FACILITY - name and address where tanks are located: Blaine Carragher-State Farm Insurance Agent 10440 West Cermak Road Westchester, IL 60154 Cook County Contact: Bruce Horek 708/567-2424
---	--

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
1	250	Heating Oil	Inert material mixed with portland cement	
2	250	Heating Oil	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

Abandonment of two tanks because they are less than 5ft from the building foundation.

Location of Tanks Being Abandoned

Tanks are located in close proximity to the building. Attempting to remove them would likely undermine the structural integrity of the building. Please see attached drawing.

CONTAMINATED SITE!

IEMA Number

2024-0585

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 708/308-4565 Email: dpiscopo@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Daniel Starks