



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2021098
Permit #:	00968-2024UPG
Request Rec'd:	08/12/2024
Approval Date:	08/12/2024 DS
Permit Expires:	02/13/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Yellow Management, Inc. 6659 S. Wentworth Chicago, IL 60621 Cook County Contact: Mohammed Yaqoob 847/679-5398	<b>FACILITY</b> - name and address where tanks are located: Dempster Mart, Inc. 6941 Dempster Ave. Morton Grove, IL 60053 Cook County Contact: Mukhtar Khan 847/679-5398
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Premium	12,000	Currently in use	Federal
6	Gasoline - Regular	12,000	Currently in use	Federal
7	Gasoline - Regular	12,000	Currently in use	Federal

**Dispensers on the Permit**

Dispenser	Action
5/6	Sump / Sensors Changing

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Stand Alone Sump Sensor

**Summary of Work**

A failed stand-alone sensor in dispenser #5/6 will be replaced with a sensor wired to the tank monitor console to achieve positive shut-down for all products in the dispenser.

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks