



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2002280  
Permit #: 00969-2024UPG  
Request Rec'd: 08/05/2024  
Approval Date: 08/12/2024 DS  
Permit Expires: 02/13/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Des Plaines Valley Mosquito Abatement Dist. 8130 Ogden Ave Po Box 31 Lyons, IL 60534 Cook County Contact: Robert Holub 708/447-1765	<b>FACILITY</b> - name and address where tanks are located: Des Plaines Valley Mosquito Abatement Dist. 8130 Ogden Ave. P.O. Box 31 Lyons, IL 60534 Cook County Contact: Robert E. Holub 708/447-1765
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	4,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Leak Detection - Piping	European with No Test Req Suction	Replacing - Leak Detect - Piping - European with No Test Req Suction

**Dispensers on the Permit**

Dispenser	Action
1	Sump / Sensors Changing
2	Sump / Sensors Changing
3	Removing

**Dispenser 1 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

**Dispenser 2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

**Dispenser 3 Equipment**

Equipment Type	Permit Equipment	Action
----------------	------------------	--------

### Summary of Work

We will be upgrading Tank # 1 by installing new Bravo single wall containment sump. We will be install new single wall UDC sumps under dispensers 1 & 2. We will be replacing existing single wall fiberglass suction piping and installing new Ameron 2" LCX double wall suction piping.

We will install OPW vertical check valve 70S-0075 under each dispenser.

We will be upgrading existing suction dispensers to new Gasboy Atlas Suction pumps

We will relocate existing overspill on tank 1 from existing location to different bung on tank shown on drawing. We will upgrade to new OPW 1C 3112P double wall edge overspill 5 gallon

### Special Contingencies

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: 708/243-0193  
Email: dough@rstentrom.com  
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks

#### For Office Use Only

##### Dispenser 1 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

##### Dispenser 2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

##### Dispenser 3 Equipment

Equipment Type	Permit Equipment	Action
----------------	------------------	--------