



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	6010094
Permit #:	00712-2024UPG
Request Rec'd:	06/11/2024
Approval Date:	06/11/2024 DS
Amended Date:	08/13/2024 DS
Permit Expires:	12/11/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Shri Satya Said Baba, Inc. 5404 Collinsville Road Fairmont City, IL 62201 St. Clair County Contact: Gurdip Kaur 618/874-0081	FACILITY - name and address where tanks are located: Fairmont 66 5404 Collinsville Road East St. Louis, IL 62201 St. Clair County Contact: Jay Modi 618/874-0081
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	10,000	Currently in use	Federal
6	Gasoline - Premium	5,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New
Piping	Flex Connector Steel	New
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	New
Piping	Flexible Double Wall A.P.T. Poly Tech S150SC	New
Piping	Ball Valves	New
Piping	Steel Single Wall Piping	New
Spill Containment Device	Double Wall Spill Bucket	New
Overfill Prevention Device	Ball Float Vent Valve Emco Wheaton A75	Removing
Overfill Prevention Device	Overfill Drop Tube Valve	New
Piping	Other Steel Riser	New

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Piping	Ball Valves	New
Piping	Other Steel Riser	New
Piping	Fiberglass Single Wall Piping Ameron Dualoy 3000/L	New
Piping	Flexible Double Wall A.P.T. Poly Tech S150SC	New
Piping	Flex Connector Steel	New
Overfill Prevention Device	Overfill Drop Tube Valve	New
Overfill Prevention Device	Ball Float Vent Valve Emco Wheaton A75	Removing
Piping	Shear Valves	New
Piping	Steel Single Wall Piping	New
Spill Containment Device	Double Wall Spill Bucket	New

Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
7/8	New

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↳ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

The existing store is being demolished and a new store is being built directly behind the old store. The existing vent lines will be moved to the new store. New dispenser sumps will be installed at dispensers 1/2 and 3/4. The existing UDC sump at dispenser 5/6 will remain. We are adding a new dispenser 7/8. We will install a new UDC with sump sensor for 7/8. New APT DW product piping will be installed from the STP to dispenser 5/6 and to new dispenser 7/8. All the existing islands will be removed and new Waayne Ovation 2 dispensers installed at grade. The product piping from the STP sumps to dispenser 5/6 was damaged during construction and will be replaced. A separate piping removal permit will be applied for.

Special Contingencies

Amendment Reason:

The existing APT product piping was damaged during excavation and new APT will be installed. Spill buckets were damaged during construction and need to be replaced

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/267-1231 Email: terrys@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,

Daniel S. Starks

Daniel Starks

For Office Use Only

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
-----------------------	-------------------------	---------------