

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 1000467
Permit #: 00982-2024UPG
Request Rec'd: 08/14/2024
Approval Date:08/15/2024 DS
Permit Expires: 02/18/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

City of De Kalb 164 E. Lincoln Hwy. De Kalb, IL 60115 De Kalb County

Contact: April Beeman 815/748-8102

FACILITY

- name and address where tanks are located:

City of DeKalb Public Works 1316 Market Street De Kalb, IL 60115

De Kalb County

Contact: Andy Raih 815/748-2040

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Diesel Fuel	10,000	Currently in use	Federal
7	Gasoline - Regular	12,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor

Summary of Work

Install positive shutdown for the gasoline and diesel sump sensors.

Special Contingencies

Oaniel J. Starke

PERSON, FIRM OR COMPANY PERFORMING WORK:				
Contact Person: Warren Cherner				
Phone: 847/465-4000				
Email: warren@metrotank.com Contractor License # IL102 Exp. 2/7/2026				

Sincerely,

Daniel Starks