



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 5020251  
Permit #: 00984-2024ABN  
Request Rec'd: 08/13/2024  
Approval Date: 08/15/2024 DS  
Permit Expires: 02/18/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Thorntons, LLC 2600 James Thornton Way Louisville, KY 40245 Jefferson County Contact: Maggie Seauth 502/579-3646	<b>FACILITY</b> - name and address where tanks are located: Thorntons #370 2208 Peoria Road Springfield, IL 62707 Sangamon County Contact: Mark Gray 217/306-4316
--	---

**Tanks on the Permit**

Tank #	Capacity	Product	Fill Material	Comments
4	12,000	Gasoline - Regular	Inert material mixed with portland cement	
5	12,000	Gasoline - Mid-grade	Inert material mixed with portland cement	
6	12,000	Diesel Fuel	Inert material mixed with portland cement	
7	4,000	Diesel Fuel	Inert material mixed with portland cement	

**Explanation of Waiver for Abandonment**

The tanks in question come with in a couple feet of the store foundation. Cant remove without damage to the sidewalk and foundation. See attachment. Tanks inside the dotted line. We are not positive on the existing piping runs.

**Location of Tanks Being Abandoned**

Tanks are located in close proximity to the building foundation as shown in site drawing. Attempting to remove the tanks would undermine the structural integrity of the building.

**Location of Piping Being Abandoned**

Piping to be removed under a separate permit.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313	Contact Person: Glen Davis Phone: 515/601-6635 Email: jfranklin@senecaco.com Contractor License # IL598 Exp. 2/23/2026

Sincerely,

Daniel Starks