



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 1014530
Permit #: 00988-2024UPG
Request Rec'd: 08/15/2024
Approval Date: 08/15/2024 DS
Permit Expires: 02/18/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: J I Corporation 412 Wedgewood Lane Belvidere, IL 61008 Boone County Contact: Jamal Chaudary 815/544-0706 | FACILITY - name and address where tanks are located: First Stop Mart #2 171 South Appleton Belvidere, IL 61008 Boone County Contact: Aousaf Chaudaary 815/744-0706 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 4 | Gasoline - Premium | 8,000 | Currently in use | Federal |
| 5 | Diesel Fuel | 6,000 | Currently in use | Federal |
| 6 | Gasoline - Regular | 15,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Summary of Work

-Upgrading from single wall spill buckets to double wall spill buckets.
-breaking concrete, Removal of old single wall spill buckets, installation of new double wall spill buckets at grade level, installation of rebars and concrete back
-hydrostatic testing of spill buckets

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

American Petroleum Solutions LLC
2911 Lund avenue apt 8
Rockford, IL 61109

Contact Person: Haibat Khan
Phone: 909/312-9449
Email: apetro.office@gmail.com
Contractor License # IL002454 Exp. 5/21/2026

Sincerely,



Daniel Starks