



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2003540  
Permit #: 00990-2024UPG  
Request Rec'd: 08/15/2024  
Approval Date: 08/15/2024 DS  
Permit Expires: 02/18/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Village of Gurnee 325 North O'Plaine Road Gurnee, IL 60031 Lake County Contact: Craig Lambrecht 708/623-7672	<b>FACILITY</b> - name and address where tanks are located: Village of Gurnee Public Works 1151 Kilbourne Road Gurnee, IL 60031 Lake County Contact: Craig Lambrecht 708/623-7672
--	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	8,000	Currently in use	Federal
6	Diesel Fuel	6,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	New

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	New

**Summary of Work**

Replacing existing Veeder Root console with new Veeder Root TLS4B console to work with existing probes and tank interstice sensors.

**Special Contingencies**

**NOTE: This permit is to add a new console for the existing sensors.**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: natem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks