



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Replacement of 01301-2023UPG

FOR OFFICE USE ONLY
Facility #: 2000878
Permit #: 00991-2024UPG
Request Rec'd: 08/15/2024
Approval Date: 08/15/2024 DS
Permit Expires: 02/18/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Zion Benton Township High School 1ZB Way 21st Street & Kenosha Rd. Zion, IL 60099 Lake County Contact: ChrisClark 847/731-9792	FACILITY - name and address where tanks are located: Zion Benton High School, Transportation Dept. 1 ZB Way, 21st Street & Kenosha Road Zion, IL 60099 Lake County Contact: Larry Molback 847/731-9731
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	6,000	Currently in use	Federal
3	Diesel Fuel	6,000	Currently in use	Federal
4	Diesel Fuel	10,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel iTouch

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel iTouch

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Omntec Proteus-K (OEL8000IIK4)	Replacing - Leak Detect - Tank - Automatic Tank Gauging OPW Site Sentinel iTouch

Summary of Work

Install new Omnitek ATG system supplied by Mankoff Industries and Program / Start-up.
Existing wiring to be reused.
Probes and Console
only (no sensors)


Special Contingencies

Replacement Reason:

Final Inspection wasn't scheduled with Inspector prior to permit expiration.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Interstate Pump and Tank, LLC 901 Niagara Street Waukesha, WI 531863817	Contact Person: Dan McMahon Phone: 262/524-8494 Email: dan@interstatepumpandtank.com Contractor License # IL002423 Exp. 6/19/2025

Sincerely,



Daniel Starks