



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2012723
Permit #: 01002-2024CAT
Request Rec'd: 08/16/2024
Approval Date: 08/19/2024 DS
Permit Expires: 02/19/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: AZ SPE, LLC 12346 S. Keeler Ave. Alsip, IL 60803 Cook County Contact: Ahmed Moctar 312/375-9105	FACILITY - name and address where tanks are located: Saraf, Inc. 3600 Berdnick Street Rolling Meadows, IL 60008 Cook County Contact: Khader Zahdan 708/372-6732
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	6,000	Currently in use	Federal
2	Gasoline - Regular	6,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal
4	Diesel Fuel	6,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Replacing eight (8) Impressed Current Anodes following installation drawing in Site Junction Box. Anodes are no longer working with rectifier showing 0.00 Amps output. Anodes will be drilled into the ground to a depth of 10-15 feet and installed with coke breeze backfill and wires attached to existing cables from junction box if continuous. If cables are found broke, they will be replaced/repared before attaching anodes.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Advanced Corrosion Control Technologies., Inc. 4664 North DuBay Drive Mosinee, WI 54455	Contact Person: Timothy Sievert Phone: 262/960-3665 Email: timothysievert@gmail.com Contractor License # IL2072 Exp. 3/22/2026

Sincerely,



Daniel Starks