



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 1009897
Permit #: 01003-2024CAT
Request Rec'd: 08/16/2024
Approval Date: 08/19/2024 DS
Permit Expires: 02/19/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Angelkrishna Corp. 1180 N. 7th Street Rochelle, IL 61068 Ogle County Contact: Umesh Patel 201/844-4567 | FACILITY - name and address where tanks are located: Angelkrishna Corp. 1180 N. 7th Street U.S. Hwy 251 & Rt. 1 Rochelle, IL 61068 Ogle County Contact: Yamini Patel 201/844-4567 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 4 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 5 | Gasoline - Premium | 12,000 | Currently in use | Federal |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------------|---------------------------------------|---|
| Corrosion Protection - Tank | Sacrificial Anode Cathodic Protection | Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------------|---------------------------------------|---|
| Corrosion Protection - Tank | Sacrificial Anode Cathodic Protection | Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection |

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

We plan to add two (2) 32 lb. Magnesium Anodes to each tank similar to the original design. The tanks will be surveyed after anodes are installed.

| | |
|---|---|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Advanced Corrosion Control Technologies., Inc. 4664 North DuBay Drive Mosinee, WI 54455 | Contact Person: Timothy Sievert Phone: 262/960-3665 Email: timothysievert@gmail.com Contractor License # IL2072 Exp. 3/22/2026 |

Sincerely,

Daniel J. Starks

Daniel Starks