



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 1028139  
Permit #: 01004-2024ENT  
Request Rec'd: 08/16/2024  
Approval Date: 08/19/2024 DS  
Permit Expires: 02/19/2025

**Permit for HOTWORK / ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances**

Permission to enter underground storage tank(s) is hereby granted. Such tank entry must be in complete accordance with all sections and procedures specified in 41 Illinois Administrative Code Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Wahe, Inc. 107 Terra Firma Lane Volo, IL 60020 Lake County Contact: C/O Raman Kaur 847/322-0817	<b>FACILITY</b> - name and address where tanks are located: Yuvi Oil d/b/a Alpine Marathon 3299 South Alpine Rd. Rockford, IL 61109 Winnebago County Contact: Kristy Lessig 847/322-0817
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status	Manway
5	Diesel Fuel	4,000	Currently in use	Federal	Install

**Summary of Work**

Cut, bust, and excavate area over 6k FRP diesel tank. Purge, enter and clean 6k FRP diesel tank in accordance with State of Illinois 175 and API-1631 regulations. Furnish and install (1) 20" manway on tank. Install 36" culvert, backfill and recover with new reinforced concrete and grade access manway.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Armor Shield of Wisconsin 3965 Hillside Road Slinger, WI 53086	Contact Person: Clayton Bennett Phone: 262/623-0300 Email: paula@armorshieldus.com Contractor License # IL1707 Exp. 4/18/2026

Sincerely,

Daniel Starks