



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2010919  
Permit #: 01016-2024CAT  
Request Rec'd: 08/20/2024  
Approval Date: 08/20/2024 DS  
Permit Expires: 02/20/2025

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: CIMA Developers, LP 30W180 Butterfield Rd. Warrenville, IL 60555 Du Page County Contact: Dan Soltis 630/715-1341	<b>FACILITY</b> - name and address where tanks are located: Pride of Villa Park 151 W. North Avenue Villa Park, IL 60187 Du Page County Contact: Myisha Harrell 630/363-2808
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
6	Gasoline - Regular	15,000	Currently in use	Federal

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**Summary of Work**

Install two 20 pound high potential magnesium anodes on the regular 6 tank at 10' spacing, 1' below tank bottom, through a mini test station and bonding to the PP2 wire.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Tanknology 880 Church Road Elgin, IL 60123	Contact Person: Linda Przydzial Phone: 512/380-7117 Email: dhollander@tanknology.com Contractor License # IL2089 Exp. 3/4/2026

Sincerely,

Daniel Starks