

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 6036707
Permit #: 01044-2024UPG
Request Rec'd: 08/26/2024
Approval Date:08/27/2024 DS
Permit Expires: 02/27/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS
- Corporation, partnership, or other business entity:

Martin & Bayley, Inc.
P.O. Box 385
Carmi, IL 62821
White County
Contact: Landon Bayley 618/382-2334Ext.248

FACILITY
- name and address where tanks are located:
Hucks #310
110 South Main
Dupo, IL 62239
St. Clair County
Contact: Tiffany Jackson 618/382-2334

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 2 | Gasoline - Premium | 12,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|--|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300 |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|--|--|
| | Automatic Tank Gauging Veeder Root TLS 450 Plus | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300 |

Summary of Work

Remove TLS & Install 450+

Oaniel J. Starke

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | | |
|---|--|--|
| Hinderliter Construction & Maint., Inc. 3601 North St. Joseph Avenue Evansville, IN 47720 | Contact Person: Mark Hinderliter Phone: 812/425-4137 Email: permits@hci4.com Contractor License # IL646 Exp. 7/3/2026 | |

Sincerely,

Daniel Starks