



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	2013595
Permit #:	01045-2024ABN
Request Rec'd:	08/26/2024
Approval Date:	08/27/2024 DS
Permit Expires:	02/27/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity:	FACILITY - name and address where tanks are located:
Zaineb Zakir Group, Inc. 5049 W. 79th Street Burbank, IL 60459 Cook County Contact: Zaineb Munshi 708/499-5049	Citgo 5049 West 79th Street Burbank, IL 60459 Cook County Contact: Claudia Esquivel 709/499-5049

Tanks on the Permit For Piping Only

Tank #	Capacity	Product	Fill Material	Comments
5	12,000	Gasoline - Regular	Piping Capped Off	Piping capped From dispenser1&2 TO 3&4

Explanation of Waiver for Abandonment

The proposed abandonment in place for the regular unleaded line from dispenser 1/2 to 3/4 was due to a failed product line without the means for obtaining replacement parts. With the lines being old environ and replacement parts and fittings obsolete, the best course of action is to abandon in place to protect the still in use Premium line and avoid any further issues.

Thank you
Innovative Constructions

Location of Piping Being Abandoned

The proposed abandonment in place for the regular unleaded line from dispenser 1/2 to 3/4 was due to a failed product line without the means for obtaining replacement parts. With the lines being old environ and replacement parts and fittings obsolete, the best course of action is to abandon in place to protect the still in use Premium line and avoid any further issues.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Innovative Constructions Technology LLC 245 W Roosevelt Rd Building 4, Unit 28 West Chicago, IL 60185	Contact Person: Raju penumatsa Phone: 630/747-3404 Email: iconstructions81@gmail.com Contractor License # IL002453 Exp. 2/7/2026

Sincerely,

Daniel Starks