



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 7033883  
Permit #: 01046-2024UPG  
Request Rec'd: 08/27/2024  
Approval Date: 08/27/2024 DS  
Permit Expires: 02/27/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Flamm Orchards, Inc. 8760 Old Hwy 51 N Cobden, IL 62920 Union County Contact: Parker Flamm 618/893-4241	<b>FACILITY</b> - name and address where tanks are located: Flamm Orchards, Inc. R. R. #2, Box 875 Cobden, IL 62920 Union County Contact: Parker Flamm 618/893-4241
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	6,000	Currently in use	Federal
4	Diesel Fuel	6,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 200	New
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Franklin Fueling Systems EVO 200	New
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	New

**Summary of Work**

Removing the existing tank monitor and installing a new Evo 200 ATG with printer. Also installing 3 new sump sensors and an interstitial sensor.

## Special Contingencies

### PERSON, FIRM OR COMPANY PERFORMING WORK:

Mid-South Steel Products, Inc.  
2071 Corporate Circle Drive PO Box 277  
Cape Girardeau, MO 63703

Contact Person: Billy Thorne  
Phone: 573/335-5529  
Email: billy@midsouthsteel.com  
Contractor License # IL1194 Exp. 8/17/2026

Sincerely,



Daniel Starks

### For Office Use Only

#### Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated in Single Wall STP/Tanktop Sump	Removing

#### Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated in Single Wall STP/Tanktop Sump	Removing

#### Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated in Single Wall UDC Sump	Removing