

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 1035597
Permit #: 01048-2024UPG
Request Rec'd: 08/27/2024
Approval Date:08/28/2024 DS
Permit Expires: 02/28/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS- Corporation, partnership, or other business entity:
Kelley Williamson Company

1132 Harrison Avenue Rockford, IL 61104 Winnebago County

Contact: Debbie Viederis 815/387-6243

FACILITY

- name and address where tanks are located:

Dixon Mobil Mart 1300 N. Galena Dixon, IL 61021 Lee County

Contact: Marisa Swenson 815/397-9410

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|----------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 2 | Gasoline - Mid-grade | 8,000 | Currently in use | Federal |
| 3 | Gasoline - Premium | 8,000 | Currently in use | Federal |
| 4 | Diesel Fuel | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|------------------|---|
| Leak Detection - Tank | , J | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|------------------|---|
| Leak Detection - Tank | 5 5 | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---|---|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 4 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|---|--|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Summary of Work Replacing existing TLS350 with TLS450plus

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|---|
| Oil Equipment Company, Inc. 4701 Lien Road Madison, WI 53704 | Contact Person: TJ Winkler Phone: 608/354-1992 Email: msobczak@oilequipment.com Contractor License # IL1318 Exp. 11/13/2024 |

Sincerely, Daniel J. Starks

Daniel Starks