



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2000233
Permit #: 01058-2024CAT
Request Rec'd: 08/29/2024
Approval Date: 08/29/2024 DS
Permit Expires: 02/28/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Speedway, LLC P.O. Box 1500 Springfield, OH 45501 Clark County Contact: Zachery Davis 937/203-7827	FACILITY - name and address where tanks are located: Speedway #7372 2932 Belvidere Street Waukegan, IL 60085 Lake County Contact: Travis Powell 937/863-6513
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Mid-grade	10,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal
3	Gasoline - Regular	10,000	Currently in use	Federal
4	Gasoline - Premium	10,000	Currently in use	Federal
5	B-11	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP

NACE Certified Designer

NACE Certified Designer Number

Method of Integrity Assessment of Tanks


Special Contingencies

Summary of Work

Install three 5-pound high potential magnesium anodes through a sac test station on each STP flexible connector (5)

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Tanknology 880 Church Road Elgin, IL 60123	Contact Person: Linda Przydzial Phone: 512/380-7117 Email: dhollander@tanknology.com Contractor License # IL2089 Exp. 3/4/2026

Sincerely,



Daniel Starks