

# City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2021069 Permit #: 01072-2024UPG Request Rec'd: 09/03/2024 Approval Date: 09/03/2024 Permit Expires: 03/05/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

RDK Ventures, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 Du Page County

Contact: Elizabeth Sauser 708/748-3496

**FACILITY** 

- name and address where tanks are located:

Circle K #6803 5701 North Broadway Chicago, IL 60660 Cook County

Contact: Manager Manager 773/275-0161

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Premium	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal

#### Tank 1 Equipment

<b>Equipment Type</b>	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Other Steel Riser - New riser for vapor	New
Piping	Other Steel Riser - New riser for fill	New

# **Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Other Steel Riser - New riser for vapor	New
Piping	Other Steel Riser - New riser for fill	New
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

#### **Summary of Work**

New fill and vapor risers being installed on both Premium tanks # 1 and 2. Replacing overspill buckets and overfill drop tubes on both Premium tanks # 1 and 2

## **Special Contingencies**

# PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448 Contact Person: Ron Anderson

Phone: 708/560-5590

Email: keith@andersonpump.com

Contractor License # IL002275 Exp. 5/21/2026

Sincerely,

Sean Keane