



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2016148
Permit #: 01081-2024ABN
Request Rec'd: 09/04/2024
Approval Date: 09/04/2024 DS
Permit Expires: 03/05/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Runa Business Enterprises 14209 Lincoln Avenue Dolton, IL 60419 Cook County Contact: Raja M Xagub	FACILITY - name and address where tanks are located: Dolton Gas, Citgo 14209 South Lincoln Dolton, IL 60419 Cook County Contact: Raja M Xaqub 773/284-1855
---	---

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
2	8,000	Gasoline - Regular	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

The tank is located next to an active fuel tank. If the tank would be removed it would affect the integrity of the active fueling system.

The piping will also be abandoned in place as well by draining and capping. Removal of the piping will also affect the integrity of the active fueling system.

Location of Tanks Being Abandoned

Tank is in close proximity of an existing tank that will remain in use, as shown in site plan

Location of Piping Being Abandoned

Piping crosses over tanks that are to remain in use, as shown in site plan

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Orivne, Inc. PO Box 46249 Chicago, IL 606460249	Contact Person: Mike Leyden Phone: 312/656-2009 Email: mleyden@orivne.us Contractor License # IL002408 Exp. 5/1/2025

Sincerely,

Daniel Starks