



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2019453
Permit #: 01104-2024UPG
Request Rec'd: 09/09/2024
Approval Date: 09/09/2024
Permit Expires: 03/11/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 4443 Ashland Real Estate, Inc. 4443 Ashland Avenue Chicago, IL 60609 Cook County Contact: Binoy Poothurail 847/409-0344	FACILITY - name and address where tanks are located: 4443 Ashland Real Estate, Inc. 4443 S. Ashland Ave. Chicago, IL 60609 Cook County Contact: Binoy Poothurail 847/409-0344
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
13	Gasoline - Premium	8,000	Currently in use	Federal

Tank 13 Equipment

Equipment Type	Permit Equipment	Action
Piping	Other Fiberglass Riser	New

Summary of Work

REPLACE RISER ON PREMIUM TANK PROBE

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Superior Petroleum Marketers, Inc. 2336 Albright Lane P. O.Box 4648 Wheaton, IL 601894648	Contact Person: Steve Tuttle Phone: 630/588-1198 Email: tuttle.steve11@gmail.com Contractor License # IL2087 Exp. 2/4/2026

Sincerely,

Sean Keane