



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2047788
Permit #: 01107-2024ABN
Request Rec'd: 09/09/2024
Approval Date: 09/10/2024
Permit Expires: 03/11/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Velinda Alexander 1201 E 172nd Street South Holland, IL 60475 Contact: Velinda Alexander 708/846-7878	FACILITY - name and address where tanks are located: True to Life Foundation 1710-1714 E. 87th Street Chicago, IL 60617 Cook County Contact: Velinda Alexander 708/846-7878
--	--

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
1	550	Heating Oil	Inert material mixed with portland cement	
2	550	Heating Oil	Inert material mixed with portland cement	
3	550	Heating Oil	Inert material mixed with portland cement	

Explanation of Waiver for Abandonment

Abandonment of (3) UST Heating Oil Tanks behind the building less than 5' from the foundation. Piping will be abandoned in place.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 708/308-4565 Email: dpiscopo@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Sean Keane