



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)785-1020

FOR OFFICE USE ONLY
 Facility # 5-007413
 Permit # 01089-2012REM
 Request Rec'd 10/12/2012
 Amended Date
 Approval Date 10/12/2012 JC
 Permit Expires 4/12/2013

Piping removal only

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

| | |
|--|--|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Joseph F. Boente Sons, Inc. 543 West Main Street, P.O. Box 288 Carlinville, IL 62626 Contact: David Boente (217) 854-3164</p> | <p>(2) FACILITY - name and address where tanks are located: Hillsboro Shell 704 South Main Hillsboro, Montgomery Co., IL Contact: David Boente (217) 532-2820</p> |
|--|--|

(3) REMOVAL OF TANKS:

- (a) **Number and size of tanks being removed:** (TK # 1) - 8,000 gallons, (TK # 2) - 4,000 gallons, (TK # 3) - 5,000 gallons, (TK # 4) - 6,000 gallons
- (b) **Description/location of piping being removed:** See site plan and contingencies section.
- (c) **Product stored in each tank:** (TK # 1, 3, 4) - Gasoline, (TK # 2) - Diesel Fuel
- (d) **Reason of tanks being removed:** Tank #1 will remain. Tanks 2,3,4 will be abandoned in place. See contingencies section.
- (e) **If tank(s) is leaking, indicate IEMA incident number:** 20120912
- (f) **Date each tank was last used:** (TK # 1), (TK # 2), (TK # 3), (TK # 4)

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES:** This permit is for the removal of piping only. There will be partial piping removed from tank #1 to a point just outside of the tank field near existing tank #2, where an existing piping section that originally came from either tank #2 or #3, extends to the existing dispenser located at the south end of the c-store (new piping from tank #1 will connect to this existing line under separate permit). The piping for tanks 2,3,4 will be completely removed (with the exception of the existing section that will hook into the new section coming from tank #1). Tanks 2,3,4 will be abandoned in place under separate permit. Inspector must refer to permits 01069-2012ABN, 01067-2012UPG, and 01068-2012INS for a more comprehensive view of the work being done at this site. Overview of the site plans for these permits is critical. An original site plan from permit #0341-97UPG is included for comparison.

| | |
|--|--|
| <p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> | |
| <p>W J Scott Company 3861 Tozer Road Springfield, IL 62707</p> | <p>Contact Person: Howard Tuttle Phone: Contractor Registration # Exp.</p> |

Sincerely,

James J Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 9/10)