



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 2-040458
Permit # 00231-2007FLX
Request Rec'd 02/22/2007
Amended Date
Approval Date 2/23/2007 JC
Permit Expires 8/23/2007

Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: R & S Enterprises 4660 W. Lawrence Ave. Chicago, IL 60630 Contact: Robert Stambolic (773) 286-5809</p>	<p>(2) FACILITY - name and address where tanks are located: Citgo 8400 N. McCormick Skokie, Cook Co., IL Contact: Robert Stambolic (773) 286-5809</p>
---	--

(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 2) - 7,000 gallons
- (b) Type of flex connector(s):* (TK # 2) - (Installing) Steel flex connectors (TK # 2) - Replaced flex connector and nipple at the premium tank submersible in the containment sump.
- (c) Product stored in each tank:* (TK # 2) - Gasoline
- (d) Corrosion Protection being installed with flex connector(s):* (TK # 2) - Existing containment sump

(4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: This work has been previously completed under emergency repair procedures. Permit #00137-2007FLX is valid until 07/29/07 to install sacrificial anodes to flex connectors at the submersible sumps for tanks 1,2,3.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Sheffield Tank Co. Forest View, IL 60402	Contact Person: Phone: Contractor Registration # Exp.

Sincerely,

James J. Coffey

cc: Storage Tank Safety Specialist -
 Fire Department -
 Office Coordinator -
 Division File
 (Rev. - 1/98)