



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-006236
Permit # 00212-2007ENT
Request Rec'd 02/20/2007
Amended Date
Approval Date 2/20/2007 JC
Permit Expires 8/20/2007

Permit for ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Cicero Board of Education Dist. 99 5110 West 24th Street Cicero, IL 60650 Contact: Rick Jenkins (312) 782-0003	(2) FACILITY - name and address where tanks are located: Service Building/Bus Maintenance Facility 5835 W Roosevelt Rd Cicero, Cook Co., IL Contact: John Zalumsky (708) 863-3774
--	--

(3) ENTRY OF TANKS:

- (a) Number and size of tanks being entered:* (TK # 3, 4) - 5,000 gallons
- (b) Type of tanks:*
- (c) Product stored in each tank:* (TK # 3) - Gasoline, (TK # 4) - Diesel Fuel
- (d) Reason for tanks being entered:*
- (e) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES: Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Containment Solutions will enter, clean, inspect, and repair (if necessary). Permit application states the tanks do have a bolted manway at grade.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Phone: Contractor Registration # Exp.

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)