



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 6-039511
Permit # 00050-2007FLX
Request Rec'd 01/10/2007
Amended Date
Approval Date 1/11/2007 DS
Permit Expires 7/11/2007

**Permit for UPGRADE or REPAIR of FLEX CONNECTOR for existing Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair flex connector(s) is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for flex connector of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company          One Convenience Blvd., P.O. Box 3001          Ankeny, IA 50021-8045</p> <p>Contact: Don Martins (515) 965-6252</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Casey's General Store          710 W. Broadway St.          Sparta, Randolph Co., IL</p> <p>Contact: Glenn Norgart (515) 965-6238</p>
--	---

**(3) UPGRADE OR REPAIR OF FLEX CONNECTORS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1, 2) - 12,000 gallons
- (b) *Type of flex connector(s):* (TK # 1, 2) - Existing steel flex connectors, (TK # 1, 2) Existing Ameron single wall fiberglass
- (c) *Product stored in each tank:* (TK # 1, 2) - Gasoline
- (d) *Corrosion Protection being installed with flex connector(s):* (TK # 1, 2) - (Installing) Sacrificial anodes cathodic protection, (TK # 1, 2) Existing Fiberglass (TK # 1, 2) - Installing anodes to flex connectors at submersible sumps only

**(4) The owner must notify this Office when completion of flex connector upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for flex connector to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:** A Timely Compliance Opportunity letter was issued for this site on 12/15/06 allowing this facility 60 days to come into compliance. If compliance is not achieved by 2/13/07 the non-compliant underground storage tank(s) will be red-tagged.

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>United Petroleum Service, Inc.</p> <p>St. Louis, MO 63102</p>	<p>Contact Person:</p> <p>Phone:</p> <p>Contractor Registration #    Exp.</p>

Sincerely,

*Daniel H. Starks*

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)