



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	4040650
Permit #:	01087-2024UPG
Request Rec'd:	09/05/2024
Approval Date:	09/05/2024 DS
Amended Date:	09/11/2024 DS
Permit Expires:	03/05/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Jack Flash Properties, LLC P.O. Box 217 Effingham, IL 62401 Effingham County Contact: Lisa Wortman 217/342-7291	FACILITY - name and address where tanks are located: Jack Flash - Lake Land 4920 Lake Land Court Mattoon, IL 61938 Coles County Contact: Lori Smith 217/235-0588
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	B-11	6,000	Currently in use	Federal
3	Gasoline - Premium	5,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	New
Piping	Other Fiberglass Riser	New
Piping	Other Steel Riser	New
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Piping	Other Fiberglass Riser	New
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	New
Piping	Other Fiberglass Riser	New
Piping	Other Steel Riser	New
Spill Containment Device	Double Wall Spill Bucket	New

Summary of Work

Replacing all spill buckets, risers and manholes at the tanks. The spill buckets will get a steel riser and all other risers will be fiberglass. New electronic line leak detectors will be installed on all grades. The existing STP sumps will remain and a new conduit will be installed into the sump for the line leak detection and future sump sensors, new conduit entry boots will also be installed in place of the existing conduit entry boots.


Special Contingencies

Amendment Reason:

Owner wants to replace conduit entry boots on the STP sumps that are deteriorating.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/797-0468 Email: cbayne@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,



Daniel Starks