



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY	
Facility #:	2006925
Permit #:	01092-2024UPG
Request Rec'd:	09/06/2024
Approval Date:	09/06/2024 DS
Amended Date:	09/11/2024 DS
Permit Expires:	09/17/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Zainab, Inc. 17951 S. Halsted Street Homewood, IL 60430 (None) County Contact: Waseem Ahmed 708/590-4099	FACILITY - name and address where tanks are located: Zainab, Inc. 17945 S. Halsted Street Homewood, IL 60430 Cook County Contact: Waseem Ahmed 708/590-4099
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
4	Gasoline - Regular	20,000	Currently in use	Federal

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	Replacing - Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX

Summary of Work

We are replacing piping adapter and the flex connector inside UDC for Dispenser 3/4 and replacing 2ft of LCX piping outside the containment.

Special Contingencies

Amendment Reason:

The line leak because of the accident seems to be little bit outside the containment.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net Contractor License # IL002420 Exp. 5/22/2025

Sincerely,

Daniel J. Starks

Daniel Starks