

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

 FOR OFFICE USE ONLY

 Facility #:
 2033156

 Permit #:
 01109-2024UPG

 Request Rec'd:
 09/10/2024

 Approval Date:09/11/2024 DS
 Permit Expires:

# Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| OWNER OF TANKS<br>- Corporation, partnership, or other business entity:                 | FACILITY - name and address where tanks are located:   |
|---|--|
| RDK Ventures, LLC<br>1100 Situs Court, Suite 100<br>Raleigh, NC 27606<br>Du Page County | Circle K #6761<br>2 South 600 Route 59 / Batavia Road<br>Warrenville, IL 60555<br>Du Page County |
| Contact: Elizabeth Sauser 708/748-3496  | Contact: Ron Cole 630/393-0367   |

#### **Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | <b>Regulated Status</b> |
|--------|--------------------|----------|------------------|-------------------------|
| 1      | Gasoline - Regular | 15,000   | Currently in use | Federal                 |

### **Tank 1 Equipment**

| Equipment Type             | Permit Equipment         | Action  |
|----------------------------|--------------------------|---|
| Spill Containment Device   | Double Wall Spill Bucket | Replacing - Spill Contain Device - Double Wall Spill Bucket |
| Overfill Prevention Device | Overfill Drop Tube Valve | Replacing - Overfill Prev Device - Overfill Drop Tube Valve |
| Piping                     | Other Steel Riser        | New   |

### Summary of Work

Installing new fill riser, replacing overspill bucket and overfill drop tube on the Regular tank # 1

### Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK:                                   | ON, FIRM OR COMPANY PERFORMING WORK:   |  |
|--|--|--|
| Anderson Pump Service, Inc.<br>19659 South 97th Avenue<br>Mokena, IL 60448 | Contact Person: Ron Anderson<br>Phone: 708/560-5590<br>Email: keith@andersonpump.com<br>Contractor License # IL002275 Exp. 5/21/2026 |  |

Sincerely,

Janiel J. Starke

Daniel Starks