



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2011793
Permit #:	01112-2024CAT
Request Rec'd:	09/10/2024
Approval Date:	09/11/2024 DS
Permit Expires:	03/11/2025

**Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Krishma Enterprises, Inc. 314 South Lewis Avenue Waukegan, IL 60085 Cook County Contact: Dave Dilip 847/293-2514	<b>FACILITY</b> - name and address where tanks are located: Rashmi Quick Mart & Beer (Marathon) 314 South Lewis Avenue Waukegan, IL 60085 Lake County Contact: Dale Houston 847/293-2514
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	6,000	Currently in use	Federal
2	Gasoline - Regular	6,000	Currently in use	Federal
3	Gasoline - Premium	6,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector	Removing

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Removing

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Sacrificial Anode Flex Connector - STP	Removing

**NACE Certified Designer**  
**NACE Certified Designer Number**  
**Method of Integrity Assessment of Tanks**

**Special Contingencies**

**NOTE: Sumps must be free of water**

**Summary of Work**


Removing sacrificial anodes from piping in STP sumps. Sumps have stand alone sensors and have all been tested.

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Cardinal Compliance LLC  
1058 National Parkway  
Schaumburg, IL 601734519

Contact Person: Chris Derro  
Phone: 708/603-4111  
Email: ccabay@cardinalcompliance.net  
Contractor License # IL002418 Exp. 3/21/2025

Sincerely,

  
\_\_\_\_\_

Daniel Starks