

# Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

#### FOR OFFICE USE ONLY

Facility #: 3033789
Permit #: 01116-2024CAT
Request Rec'd: 09/10/2024
Approval Date:09/11/2024 DS
Permit Expires: 03/11/2025

# <u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

## THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Casey's Retail Company

3305 SE Delaware Ave. P.O. Box 3004

Ankeny, IA 50021

Contact: Lee Lytle 515/446-6231

**FACILITY** 

- name and address where tanks are located:

Casey's General Store #1819 618 N. Main Illinois Route 78 Kewanee, IL 61443 Henry County

Contact: Kayla Goodin 515/965-6238

#### Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

# **Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Corrosion Protection -	Sacrificial Anode Flex Connector	Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex
Piping	- STP	Connector - STP

NACE Certified Designer NACE Certified Designer Number Method of Integrity Assessment of Tanks

## **Special Contingencies**

# **Summary of Work**

Replace sacrificial anode in RUL STP on the flex connector

PERSON, FIRM OR COMPANY PERFORMING WORK:

Protanic, LLC 658 North Progress Drive PO Box 80265

Janiel J. Starke

Saukville, WI 53080

Contact Person: Kylie Krombach

Phone: 262/268-1150

Email: danc@protanicinc.com

Contractor License # IL1413 Exp. 3/15/2026

Sincerely,

**Daniel Starks**