



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2017072
Permit #: 01132-2024UPG
Request Rec'd: 09/12/2024
Approval Date: 09/16/2024 DS
Permit Expires: 03/18/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Lutheran General Hospital 1775 West Dempster Park Ridge, IL 60068 Cook County Contact: Garry Applebaum 847/723-5088	FACILITY - name and address where tanks are located: Lutheran General Hospital 1775 West Dempster Park Ridge, IL 60068 Cook County Contact: Gary Applebaum 847/723-5088
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	6,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve

Summary of Work

Changing singlewall EBW belowgrade spill container to doublewall EBW belowgrade spill container
Replacing damaged OPW 61SOP coaxial Overfill valve with EBW 708693901 Coaxial Overfill Valve

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Interstate Pump and Tank, LLC 901 Niagara Street Waukesha, WI 531863817	Contact Person: Dan McMahon Phone: 262/524-8494 Email: dan@interstatepumpandtank.com Contractor License # IL002423 Exp. 6/19/2025

Sincerely,

Daniel Starks