



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4021691
Permit #: 01136-2024CAT
Request Rec'd: 09/13/2024
Approval Date: 09/16/2024 DS
Permit Expires: 03/18/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Meldi Mata 24, LLC 105 S. Michigan Avenue Marshall, IL 62441 Clark County Contact: Rex Patel 352/615-6992	FACILITY - name and address where tanks are located: Sriyan 19, LLC - Marathon 105 South Michigan Avenue Marshall, IL 62441 Clark County Contact: Rex Patel 352/615-6992
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	12,000	Currently in use	Federal
4	Gasoline - Premium	8,000	Currently in use	Federal
5	Diesel Fuel	8,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Sacrificial Anode Cathodic Protection	Replacing - Corrosion Prot - Tank - Sacrificial Anode Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work


Complete the one call for location of utilities, CP testing to confirm Native readings the day of installation, complete sawcutting and removal of the concrete in areas needed for the installation of (4) 32-pound High Output Magnesium anodes, with 100' leads on each of the (3) existing UST'S. Complete the excavation needed via hydro excavation, installation of the anodes, saturation of the anodes and current output readings of each anode. Connection of the anodes to each of the tanks via pin brazing, testing of the connections for resistance, and initial testing of the tanks at the time of installation. Installation of the test stations and labeling. Complete backfill of the areas excavated. Completion of an installation CP survey and the 60 day CP Survey. Testing between if needed. Reporting as required. Note: Sacrificial anodes to be installed outside of the tank backfill.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Bolin Enterprises, Inc.
506 North East 15th Street PO Box 70
Casey, IL 62420

Contact Person: Scott Justice
Phone: 217/251-6094
Email: scott.justice@bolininc.com
Contractor License # IL002333 Exp. 10/10/2024

Sincerely,



Daniel Starks