



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022887
Permit #: 01141-2024ABN
Request Rec'd: 09/08/2024
Approval Date: 09/16/2024 DS
Permit Expires: 03/18/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: J & B Oaklawn, Inc. 5970 W. 95th Street Oak Lawn, IL 60453 Cook County Contact: Jibby Thomas 630/220-7194	FACILITY - name and address where tanks are located: Oak Lawn Express Mart, Inc. 5870 W. 95th Street Oak Lawn, IL 60453 Cook County Contact: Musleh Sharif 630/220-7194
---	--

Tanks on the Permit

Tank #	Capacity	Product	Fill Material	Comments
7	10,000	Gasoline	Sand	

Explanation of Waiver for Abandonment

the tank is in the middle of 2 existing operating tanks to remain in place and if removed would compromise the other two tanks. This makes removal infeasible. The piping will also be abandoned in place as it is also infeasible to remove without damaging piping connected to dispensers and other takes that will remaining in operation.

Location of Tanks Being Abandoned

the tank is in the middle of 2 existing operating tanks to remain in place and if removed would compromise the other two tanks. This makes removal infeasible. The piping will also be abandoned in place as it is also infeasible to remove without damaging piping connected to dispensers and other takes that will remaining in operation.

Location of Piping Being Abandoned

the tank is in the middle of 2 existing operating tanks to remain in place and if removed would compromise the other two tanks. This makes removal infeasible. The piping will also be abandoned in place as it is also infeasible to remove without damaging piping connected to dispensers and other takes that will remaining in operation.

CONTAMINATED SITE!

IEMA Number
2024-0539

Special Contingencies

NOTE: Only sand can be used as the fill material to abandon the tank.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Perry Environmental, Inc. 900 South Spring Street Springfield, IL 62704	Contact Person: julie keebler Phone: 217/523-5446 Email: mkeebler@perryenvironmental.net Contractor License # IL002445 Exp. 4/6/2026

Sincerely,

Daniel J. Starks

Daniel Starks