



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7015182
Permit #: 01142-2024UPG
Request Rec'd: 09/16/2024
Approval Date: 09/16/2024 DS
Permit Expires: 09/27/2024

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Southern FS, Inc. 2002 East Main Street P.O. Box 728 Marion, IL 62959 Williamson County Contact: Caleb Huelsmann 618/993-2833	FACILITY - name and address where tanks are located: Southern FS, Inc. 5 West Robinson Harrisburg, IL 62946 Saline County Contact: Dan Evans 618/253-8977
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	12,000	Currently in use	Federal

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	Replacing - Piping - Flexible Double Wall A.P.T. Poly Tech S175SC

Summary of Work

replacing the shear valve on the Satellite dispenser 5

Special Contingencies

NOTE: UDC must be installed under a separate upgrade permit if not already existing

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/797-0468 Email: cbayne@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,

Daniel Starks