



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2040712
Permit #: 00804-2024UPG
Request Rec'd: 07/03/2024
Approval Date: 07/09/2024
Amended Date: 09/16/2024 Chi
Permit Expires: 01/09/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: T & R Properties, LLC 6989 Fieldstone Drive Burr Ridge, IL 60527 Du Page County Contact: Mohammad T. Motan 708/243-0756	FACILITY - name and address where tanks are located: A.H. Petro Group , Inc. 6124 S. Ashland Avenue Lessee Chicago, IL 60636 Cook County Contact: Shakil YasinAhmed 773/759-3314
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	E85	4,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 300c with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300c with CSLD
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection
Overfill Prevention Device	Overfill Drop Tube Valve	Replacing - Overfill Prev Device - Overfill Drop Tube Valve
Piping	Ball Valves	New
Piping	Other Submersible Pump	New

Summary of Work

Changing the product in the existing Diesel tank to E85 and equipment compatible with E85

AMENDMENT - Discovery of single wall pipe (not double wall). No need for sensor or positive shutdown. Amendment to remove sensor from sump and from OSFM database for that tank

Special Contingencies

Amendment Reason:


OSFM database shows double wall flex for T3 E85 product. While on site for the E85 conversion, the tech discovered that the product pipe is Total Containment single wall pipe. Amending permit to remove sensor replacement

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: ben.olthoff@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

A handwritten signature in black ink that reads "Sean Keane". The signature is written in a cursive, flowing style. Below the signature is a solid horizontal line.

Sean Keane