



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 6015993  
Permit #: 01146-2024UPG  
Request Rec'd: 09/16/2024  
Approval Date: 09/16/2024 DS  
Permit Expires: 03/18/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Boondocks Market P.O. Box 145 Bartelso, IL 62218 Clinton County Contact: Shelly McRoy 618/765-2246	<b>FACILITY</b> - name and address where tanks are located: Boondocks Market 401 Carlyle Road Bartelso, IL 62218 Clinton County Contact: Shelly Mcroy 618/765-2246
--	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Gasoline - Regular	10,000	Currently in use	Federal
4	Diesel Fuel	10,000	Currently in use	Federal

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Tank 4 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Dispensers on the Permit**

Dispenser	Action
1/2	Sump / Sensors Changing

**Dispenser 1/2 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

**Summary of Work**

The diesel emergency valve is bad. The existing dispenser sump is too small to get the work done. We will install a new sump, replace both emergency valves, flex connectors, FRP piping as needed to install the sump and steel nipples if needed.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/797-0468 Email: cbayne@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,



Daniel Starks

<b>For Office Use Only</b>		
<b>Dispenser 1/2 Equipment</b>		
<b>Equipment Type</b>	<b>Permit Equipment</b>	<b>Action</b>
Dispenser	Not Installed UDC Sump	Removing